



APPLICATION

Replacement panel with duct flanges for attaching horizontal duct.

INSTALLATION OF SHZRETPNL180300

1. Remove the damper assembly from its container and inspect for damage or shortages
2. Locate and remove the evaporator access panel. Retain the screws for step 3.
3. Attach the replacement evaporator panel to the side of the machine using the screws from step 2 and weatherproof with silicone or other approved sealant.
4. Attach duct over flanges of panel.

